

Operational Permit Application Motor-Fuel Dispensing Facilities & Repair Garages

Work or activity requiring a permit shall not commence until such work or activity has been inspected and authorized with a valid permit. Violation of this condition may result in additional permit or inspection fees.

GENERAL INFORMATION (to be completed by the permit a	pplicant) (PLEASE PRII	NT)
Business Name:		
Address:		
City:	State:	Zip:
Contact Person:	Phone No.	
Email Address:		
LOCATION OF PERMITTED ACTIVITY (if different than above	e) (PLEASE PRINT)	
Business Name:		
Address:		
City:	State:	Zip:
PERMIT BILLING (if different than above) (PLEASE PRINT)	(Permits will be bil	led by the City of Bellevue)
Business Name:		
Address:		
City:	State:	Zip:
Contact Person:	Phone No.	
Email Address:		
Click here for the current permit fee. Note: This fee will change Consumer Price Index. Governmental or non-profit organizations a provide IRS documentation for non-profit status. Temporary use permits are invoiced within 30 days of permits are invoiced January each year. All permits are subject to a late fee if not paid within 30 days.	are exempt from permit mit issuance.	
Applicant Signature Do	ate	
FIRE PREVENTION OFFICE USE ONLY:		
Specific Permit Conditions:		
Application Disposition: \square Approved \square Denied		
Reason for Denial:		
Reviewed / Inspected Bv:	Date:	

PERMIT CONDITIONS

MOTOR-FUEL DISPENSING FACILITIES & REPAIR GARAGES

The following conditions shall be adhered to at all times for the permit to be valid.

- 1. An operational permit is required for operation of repair garages and automotive, marine and fleet motor fuel-dispensing facilities.
- 2. A separate operational permit is required for flammable and combustible liquid storage / use within a building, spray finishing, hot work operations, and LP-Gas storage / use.
- 3. Cleaning of parts shall be conducted within an approved parts-cleaning machine.
- 4. Self-closing metal cans shall be used for oily waste materials.
- 5. Portable fire extinguishers shall have a minimum 2A:20:BC rating, with a maximum 75 ft travel distance.
- 6. Sources of ignition shall not be located within 18 inches of the floor.
- 7. Smoking shall not be allowed in repair garages.
- 8. Dispensing devices shall be located such that all portions of the vehicle being fueled will be on the premises of the facility.
- 9. An identified and readily accessible emergency disconnect switch shall be provided at an approved location within 100 feet, but not less than 20 feet of the fuel dispensers.
- 10. Operating instructions and warning signs shall be conspicuously posted at each fuel dispenser.
- 11. Attended self-service motor fuel-dispensing facilities shall have at least one qualified attendant on duty while the facility is open for business.
- 12. Unattended self-service motor fuel-dispensing facilities shall be equipped with an emergency procedures sign and a telephone not requiring a coin to operate in an approved location.
- 13. Smoking and open flames shall be prohibited in areas where fuel is dispensed. The engines of vehicles shall be shut off during fueling.